




The State of New Hampshire
Department of Environmental Services



Michael P. Nolin
Commissioner

March 24, 2005

LETTER OF DEFICIENCY #WSEB 05-032
CERTIFIED MAIL 7000 0600 0023 9933 1089

Cynthia Smith
CCNest LLC
PO Box 142
East Wakefield, NH 03830

Subject: Wakefield - Public Water System: Coo Coos Nest (EPA #2398140)

Dear Ms. Smith:

The records of the Department of Environmental Services (DES) show that the Coo Coos Nest water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system supplying 15 or more services, or 25 or more people, for 60 or more days per year. As such, the water system owner is required to submit samples to the State laboratory or a State-certified laboratory for coliform bacteria analysis in compliance with NH Admin. Rule Env-Ws 325.

DES records show that the subject water system failed to submit bacteria samples and as a result Monitoring/Reporting (M/R) violations were issued for the following months:

December 2003 and November 2004

In view of the Monitoring/Reporting violations, DES believes the deficiencies can be corrected by taking the following actions:

1. **By April 7, 2005**, submit a water "make-up" sample for bacteria analysis to the state laboratory, or a state-certified laboratory, in accordance with NH Admin. Rule Env-Ws 325.

Please continue to submit water samples according to the water system's Master Sampling Schedule enclosed.

Pursuant to Env-Ws 351, owners of public water systems are required to issue public notification when a system has failed to monitor for bacteriological water quality. DES records show that the water system has failed to perform public notification for the November 2004 monitoring violation.

Letter of Deficiency #WSEB 05-032
Coo Coos Nest
March 24, 2005
Page 2 of 2


In view of the public notice violation, DES believes the deficiency can be corrected, and future violations prevented, by taking the following actions:

2. **By April 14, 2005**, carry out the public notice requirements for the November 2004 sampling violation; and
3. **By April 21, 2005**, provide proof of public notice to DES.

In the event compliance is not achieved within this period, DES may initiate formal action against you, including issuing an order requiring the deficiencies to be corrected, initiating an administrative fine proceeding, and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

Please contact Anne Bailey by phone at (603) 271-0672 or by e-mail at abailey@des.state.nh.us if you have any questions regarding this letter.

Sincerely,


Sarah Pillsbury, P.G., Administrator
Water Supply Engineering Bureau

h:\wseb\enfmon\enforce\lods\bacteria\2005\2398140 mr-pn 05-032.doc

Enclosures: Master Sampling Schedule
Public Notice Form

cc: Gretchen R. Hamel, DES Legal Unit Administrator
Town of Wakefield Health Officer
NH H&HS Restaurant Licensing
EPA, Region 1